

MOUNTAIN VIEW WATER & WASTEWATER

PO BOX 360
311 WEST MAIN ST
MOUNTAIN VIEW AR 72560

PHONE: 870-269-3293
FAX: 870-269-9158

April 6, 2018

ADEQ
Water Division
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: NPDES Permit Number: AR0020117, AFIN: 69-00011
Corrective Action Plan Response

Ms. Taylor;

This is the quarterly progress report for March 15, 2018. To date we are still working on our I&I problems. We have found a few more manholes with issues since our last letter, one was on Union St. and it was repaired on March 12, 2018 the others were manholes #36 and #41 off of and on East Washington St. these had clay stub-outs that were changed to PVC. Also we had the Force Main from Lift Station #1 up to Washington St. checked with camera by Arkansas Rural Water crew. McClelland Engineers are in the process of look at what can be done to the Force Main and the pumps at the Lift Station. We were short on work crew for a few weeks but we have adequate staff back in force weather permitting. Also some of the local plumbers have recently replaced four customer service lines that were clay pipe to PVC. We will continue to address the problem. Also is attached photos of the manholes.

If you have any question or comments please give me a call.

Sincerely,

Roger Gardner 4-6-18

Roger Gardner, Mayor City of Mountain View

off of Washington & Alley
~~Washington~~

MH # 36



Washington on Behind Ins Co #41
MTH
Clay Stub out Replaced with PVC



Union

MH 109

#2



Union fixed
Repaired #2 M#109

