

NON-COMPLIANCE NOTIFICATION

FROM: City of Mountain View
340 Westwood Ave, Off HWY 66 W
Mountain View, AR 72560

DATE: November 12, 2014

Permit #: AR0020117

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. **DISCHARGE DESCRIPTION: 001**

2. **NON-COMPLIANCE DESCRIPTION:**
NH3N value exceeded permit limit.

3. **CAUSE FOR NON-COMPLIANCE:**

Low Aeration


4. **DURATION OF NON-COMPLIANCE:**

One day, October 22, 2014


5. **CORRECTIVE ACTION BEING TAKEN:**

Increase Aeration

SIGNATURE:



**MOUNTAIN VIEW
WATER & SEWER DEPARTMENT
PO BOX 360
MOUNTAIN VIEW, AR 72560**



**ADEQ
NPDES Enforcement Section
5301 Northshore Drive
N. Little Rock, AR 72118-5317**

721185317 R015

