

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 12/01/2016 - 12/31/2016

FROM: City of Mtn.View
340 Westwood Ave, Off Hwy 66 W
Mountain View, AR 72560

DATE: 1/16/2017

PERMIT #: AR0020117

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Operator recorded the Dissolved Oxygen below the monthly permit limit.

3. CAUSE FOR NON-COMPLIANCE:

aerator was turned to low.

4. DURATION OF NON-COMPLIANCE:

The Dissolved Oxygen non-compliance description took place on December 14th, 2016.

5. CORRECTIVE ACTION BEING TAKEN:

I turned aerator up.


SIGNATURE:

Jackie E. Craig
5-22-17

MOUNTAIN VIEW WATER DEPT.
PO BOX 360, 311 W MAIN ST
MOUNTAIN VIEW AR 72560

LITTLE ROCK AR 722

22 MAY 2017 PM 3 1



ADEQ
NPDES Enforcement Section
5301 Northshore Drive
N. Little Rock, AR 72118-5317

72118-5317 95

