

# NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 7/01/2016 - 7/31/2016

**FROM:** City of Mtn.View  
340 Westwood Ave, Off Hwy 66 W  
Mountain View, AR 72560

**DATE:** 8/17/2016

**PERMIT #:** AR0020117

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Ammonia was reported over the 7 day avg permit limit one time in July.

3. CAUSE FOR NON-COMPLIANCE:

*we are changing Anaerobic Digester  
To Aerobic*

4. DURATION OF NON-COMPLIANCE:

The Ammonia violation took place on July 12th, 2016.

5. CORRECTIVE ACTION BEING TAKEN:

*Finish construction*

SIGNATURE: 