

NON-COMPLIANCE NOTIFICATION

FROM: City of Mountain View
311 West Main Street
Mountain View, AR 72560

DATE: 7/14/2015

PERMIT #: AR0020117

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Ammonia value was reported higher than the 7 day average permit limit.

3. CAUSE FOR NON-COMPLIANCE:

*Excessive flow to plant.
Turned Aerators off to
keep solids in plant*

4. DURATION OF NON-COMPLIANCE:

The Ammonia exceeded the 7 day average value on June 10 and June 17, 2015.

5. CORRECTIVE ACTION BEING TAKEN:

Turned Aerators on


SIGNATURE:



Mountain View Water Dept.
P. O. Box 360
Mountain View, AR 72560

LITTLE ROCK AR 722

20 JUL 2015 PM 3



ADEQ
NPDES Enforcement Section
5301 Northshore Drive
N. Little Rock, AR 72118-5317

72118531799

