

NON-COMPLIANCE NOTIFICATION

FROM: City of Mountain View
311 West Main Street
Mountain View, AR 72560

DATE: 10/15/2015

PERMIT #: AR0020117

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Fecal Coliform exceeded the 7 day geometric value.

3. CAUSE FOR NON-COMPLIANCE:

WASHOUT

4. DURATION OF NON-COMPLIANCE:

The Fecal Coliform exceeded the 7 day geometric value on September 2, 2015.

5. CORRECTIVE ACTION BEING TAKEN:

Put into Storm flow


SIGNATURE: _____

A handwritten signature in black ink, appearing to read "Joe [unclear]", written over a horizontal line.

Mountain View Water Dept.
P. O. Box 360
Mountain View, AR 72560

LITTLE ROCK AR

29 OCT 2015 PM



ADEQ
NPDES Enforcement Section
5301 Northshore Drive
N. Little Rock, AR 72118-5317

72118531799

