

ADEQ

ARKANSAS
Department of Environmental Quality

January 13, 2014

J.R. Henderson, Water and Sewer Superintendent
City of Mountain View
P.O. Box 360
Mountain View, AR 72560

RE: Reconnaissance Sanitary Sewer Overflow Inspection (Stone Co)
AFIN: 69-00011 NPDES Permit No.: AR0020117

Dear Mr. Henderson:

On January 8, 2014, I performed a sanitary sewer overflow (SSO) inspection at the cleanout located at 903 Oak Street in Mountain View, AR in response to a complaint. The complaint alleged that a sewer line or manhole was overflowing at this address. This inspection was conducted in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. This inspection revealed the following violations:

1. You have a work order that shows a SSO had occurred and was repaired at 903 Oak St on January 2, 2014 (the work order is attached to this report). This SSO was not reported to the Enforcement Branch of the Water Division. **This is a violation of Part II. 5 of your permit.**
2. The two (2) sewer line cleanouts at 903 Oak St still had sanitary solids and debris around them, and one line was missing its cap (see Photos 1 and 2). **This is a violation of Part II. 5.6 of your permit.**

The above items require your immediate attention. Please submit a written response to these findings to the Water Division Inspection Branch of this Department. This response should be mailed to the address at the bottom of the first page of the letter or e-mailed to **Water-Inspection-report@adeq.state.ar.us**. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e. photos) is due by **January 27, 2014**.

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY

5301 NORTHSHORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72118-5317 / TELEPHONE 501-682-0744 / FAX 501-682-0880

www.adeq.state.ar.us

Re: Reconnaissance Sanitary Sewer overflow Pump
AFIN: 69-00011 NPDES permit NO: Aro020117

corrective Action: Replaced missing cap, cleaned all
Debris from area, Replaced cover.


J. R. Henderson
Water & Sewer Dept.



MOUNTAIN VIEW WATER
PO BOX 360 311 W MAIN ST
MOUNTAIN VIEW AR 72560

LITTLE ROCK AR 722

28 JAN 2014 PM 2 L



ADEQ
5301 NORTSHORE DR
N. LITTLE ROCK AR 72118-
5317 *Water Division*

72118531799

