

ADEQ

ARKANSAS
Department of Environmental Quality

October 17, 2011

Tom Myers, Wastewater Superintendent
City of Siloam Springs
PO Box 80
Siloam Springs, AR 72761

RE: NPDES Permit No. AR0020273, AFIN 04-00106

Dear Mr. Myers:

A review of the NPDES file for the City of Siloam Springs for the period of July 1, 2011 thru July 31, 2011 reveals the following compliance issue:

The facility reported 1 violation of Part I, Section A. of NPDES Permit No.: AR0020273. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
07/31/2011	001A	Phosphorus, total (as P) (7 DA AVG, mg/L)	2.14	1.5

The Department expects the City of Siloam Springs to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

