

August 14, 2019

CERTIFIED: 9489 0090 0027 6060 6597 96

John Mark Turner, Mayor Siloam Springs P.O. Box 80 SILOAM SPRINGS, AR 72761

RE: Permit Number: AR0020273, AFIN: 04-00106 City of Siloam Springs

Dear Mayor Turner:

A review of the Permit file for the above mentioned facility for the period of January 1, 2019 through July 31, 2019 reveals the following compliance issues:

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit	Vio %
05/31/2019	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	83.5	55	52%
05/31/2019	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	2.9	1.5	93%
05/31/2019	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	5.98	2.3	160%
05/31/2019	001-A	Phosphorus, total [as P] (MO AVG, lb/d)	41.87	37	13%
05/31/2019	001-A	Phosphorus, total [as P] (MO AVG, mg/L)	1.29	1	29%
05/31/2019	001-A	Phosphorus, total [as P] (7 DA AVG, mg/L)	2.88	1.5	92%
06/30/2019	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	79.2	55	44%
06/30/2019	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	1.78	1.5	19%
06/30/2019	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	3.58	2.3	56%

The facility has reported <u>9 effluent violations</u> of Part I, Section A of Permit No. AR0020273:

Non-compliance reports with corrective actions were received by the Department. Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0840, or you may e-mail me at <u>christina.brown@adeq.state.ar.us</u>.

Letter to Siloam Springs

Sincerely,

Tristina Loun

Christina Brown Enforcement Analyst Office of Water Quality