

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020273 Discharge Number: 001

Facility: City of Siloam Springs Water Pollution Control Facility

Address: 975 Anderson Avenue

City: Siloam Springs State: AR Zip: 72761

Contact: Tony Brown Phone: 479-524-5623

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
April 1, 2019	Monthly Average		2.367	1.6
April 1, 2020	Mass, (lbs/day)		65.96	59

We feel this problem was due to:

A contributing factor for the non-compliance was due to 2 rain events on 4-11-20 and 4-12-20 both days having an estimated (.8) inches of rain. Plant operators opened a secondary biological nutrient train to help balance the incoming influent flows. Ammonia was increased and reflected on our lab test.

We plan on correcting the problem in this manner:

Time estimated that it will take to correct problem:

Sincerely,



Submitted By:

5-24-2020

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)