Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: _____City of Siloam Springs

NPDES Permit No.: AR0020273

Monitoring Period (Month/Year): 10 / 2020

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Environmental Impact	Action(s)	Ultimate Discharge Locatio		
C - Construction	D - Debris	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	JV - Jet Vac	GR - Ground	
EF - Equipment Failure	G - Grease	OEHC - Evidence of Human Contact	HC - Hydro Cleaned	SL - Spread Lime	CR - Creek / Stream / River (specify)	
LF - Line Failure	R - Rainfall (I&I)	OEEI - Evidence of Environmental Impact	HR - Hand Rodded	DD - Disinfected and	DI - Ditch	
PF - Power Failure	RO - Roots	NEAH - No Evidence of Adverse Health or	MR - Machine Rodded	Deodorized	DR - Drop Inlet	
V - Vandalism		Environmental Impact	PN - Public Notification	GP - Used Generator to	PA - Paved Area	
			EN - Referred to Engineering	Power Equipment	CB - Contained in Building	

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
					1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 -		

11-23-2020 Date

Signature of Cognizant or Ranking Official

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD to: ADEQ Office of Water Quality * 5301 Northshore Drive * North Little Rock, AR 72118