


# Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Siloam Springs Wastewater Plant NPDES Permit No.: AR0020273 Monitoring Period (Month/Year): 5 / 2021

**No Sanitary Sewer Overflows This Monitoring Period**

REPORT CODE DESCRIPTIONS					
Cause(s) of SSO		Environmental Impact	Action(s) Taken		Ultimate Discharge Location
C - Construction	D - Debris	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	JV - Jet Vac	GR - Ground
EF - Equipment Failure	G - Grease	OEHC - Evidence of Human Contact	HC - Hydro Cleaned	SL - Spread Lime	CR - Creek / Stream / River (specify)
LF - Line Failure	R - Rainfall (I&I)	OEEI - Evidence of Environmental Impact	HR - Hand Rodded	DD - Disinfected and Deodorized	DI - Ditch
PF - Power Failure	RO - Roots		MR - Machine Rodded		DR - Drop Inlet
V - Vandalism		NEAH - No Evidence of Adverse Health or Environmental Impact	PN - Public Notification	GP - Used Generator to Power Equipment	PA - Paved Area
			EN - Referred to Engineering		CB - Contained in Building

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
2400 W Central Lift Station	5-30-21	5-30-21	900	EF	NEAH	GP,HC,SL	GR
975 E Central St. MH 6-109	5-13-21	5-13-21	500	D	NEAH	MR,SL	GR

  
 \_\_\_\_\_  
**Signature of Cognizant or Ranking Official**
6-22-2021  
 \_\_\_\_\_  
**Date**

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission **NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD** to:  
 ADEQ Office of Water Quality ❖ 5301 Northshore Drive ❖ North Little Rock, AR 72118