



ARKANSAS  
Department of Environmental Quality

August 23, 2011

Emric Roll  
North Little Rock WW Utility-Faulkner Lake  
P.O. Box 17898  
North Little Rock, AR 72117-0898

RE: NPDES Permit No. AR0020303, AFIN 60-00274

Dear Mr. Roll:

A review of the NPDES file for the North Little Rock WW Utility-Faulkner Lake for the period of June 1, 2011 thru June 30, 2011 reveals the following compliance issue:

The facility reported 1 violations of Part I, Section A. of NPDES Permit No.: AR0020303. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
06/30/11	001A	pH (MINIMUM, SU)	5.94	6

The Department assumes that North Little Rock WW Utility-Faulkner Lake continues to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at [anderson@adeq.state.ar.us](mailto:anderson@adeq.state.ar.us).

Sincerely,

Alan Anderson  
Enforcement Analyst  
Water Division / Enforcement Branch

