

## Taylor, Bailey

---

**Subject:** FW: North Little Rock CAO LIS 10-218 Termination Presentation

---

**From:** Taylor, Bailey

**Sent:** Wednesday, June 27, 2018 12:16 PM

**To:** Healey, Richard; Johnson, Miles

**Subject:** RE: North Little Rock CAO LIS 10-218 Termination Presentation

Meeting notes:

- Ensure annual # of SSOs NLRWU reports matches what ADEQ has in the database, remove any duplicate submissions.
- Five Mile Creek WWTP – indefinitely deferring project to leave the door open for Sherwood’s South Plant to connect, but has been improving collection system. Currently meeting permit limits. Justify deferring project.
- Projects 13-17 (deferred) – NLWU to submit a breakdown of SSOs, if any, and the causes in the areas of the referenced projects.
  - Do the number of SSOs support the deferring of the referenced projects?
  - Oakbrook/Manor Drive Pump Station – any SSOs in that area to prove the pump upgrades were sufficient?
- What qualifies as “high water?” Keep in mind Arkansas has been having unusual rain patterns.
- NLRWU wants the flexibility to focus on rehabilitating the Lower Riverside Interceptor, a 54” line that collapsed in 2016 and runs along the Arkansas River.
- NLRWU also requested the flexibility to focus on target specific SSOs in smaller basins.

Thanks,

*Bailey Taylor*

Enforcement Analyst

Office of Water Quality

Arkansas Department of Environmental Quality

501-682-0639