



A Clean Water Agency

NORTH LITTLE ROCK WASTEWATER

January 11, 2024

Enforcement Division  
Arkansas Department of Energy & Environment  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Re: Non-compliance report for December 2023; Faulkner Lake AR0020303

The following is a description of the non-compliance for December 2023:

1. **Description of the non-compliance:**
  - a) Frequency analysis not met for TSS testing.
2. **Duration of the non-compliance:**
  - a) December 11<sup>th</sup>, 2023
3. **Cause of non-compliance:**
  - a) Laboratory Technician error, sample poured out.

**Measures to prevent or minimize the occurrence of the above non-compliances:**

- a) The Laboratory Technician has been re-instructed on the test procedure.

For further information, please call me at 501-945-7186.

North Little Rock Wastewater Utility

Marybeth Eggleston  
Environmental Compliance and Safety Manager