


Sanitary Sewer Overflow Monthly Report

Facility Name: Batesville Water Utilities
 Permit Number: AR0020702
 Reporting Period(Month/Year): January 2016

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		SSO Impact		Action(s) Taken		Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse of Environmental Impact		WO-Work Order		CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact		EC-Environmental Cleanup		Dl-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFF-Evidence of Fish Kill		HC-Hydro Cleaned		DR-Drop Inlet
R-Rainfall	RG-Roots & Grease			HR-Hand Rodded		GR-Ground Surface
RO-Roots	V-Vandalism			EN-Referred to Engineering		PA-Paved Area
				PN-Public Notification		CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
E. Main & Highland	2-92	1/4/2016	1/4/2016	Unknown	D	NEAH	EC,HC	PA,GR
2356 Lee	6-13	1/12/2016	1/12/2016	30	CO	NEAH	EC	GR
499 S. 19th st.	No #	1/26/2016	1/26/2016	50	G	NEAH	EC,HC	PA,GR


 Signature of Cognizant or Ranking Official

Date 2-8-16

"I certify under penalty of law that this document and all attachments were prepared under my direction of supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."