

BATESVILLE WASTEWATER TREATMENT PLANT

**500 River Bank Road
Batesville, Arkansas 72501
Phone (870)-698-2442 Fax 870-698-2443
wwsuper@cityofbatesville.com**

May 11, 2015

NPDES ENFORCEMENT DIVISION
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118


RE: NPDES AR0020702 AFIN: 32-00044

This letter is to notify your office that the Batesville Wastewater Treatment Plant exceeded its discharge limit for the month of April 2015, on the following parameters.

	<u>Concentration</u> <u>Monthly Avg.</u>	<u>Permit Limit</u> <u>Monthly Avg.</u>	<u>Loading Value</u> <u>Weekly Avg.</u>	<u>Permit Limit</u> <u>Weekly Avg.</u>	<u>Reported Value</u> <u>Monthly Avg.</u>	<u>Permit Limit</u> <u>Monthly Avg.</u>
a. BOD	32 mg/l	30 mg/l	52 mg/l	40 mg/l	1642 pounds	1100.9 pounds

These violations occurred in part due to the construction project and excessive rainfall. If you have any other questions or comments feel free to call anytime.

Sincerely;


Eugene Townsley
Plant Superintendent

Cc: Mr. Damon Johnson P.E.