

BATESVILLE WASTEWATER TREATMENT PLANT

500 River Bank Road

Batesville, Arkansas 72501

Phone (870)-698-2442 Fax 870-698-2443

wwwsuper@cityofbatesville.com

May 20, 2013

NPDES ENFORCEMENT DIVISION

Arkansas Department of Environmental Quality

5301 Northshore Drive

North Little Rock, Arkansas 72118


RE: NPDES AR0020702 AFIN: 32-00044

This letter is to notify your office that the Batesville Wastewater Treatment Plant exceeded its discharge limit for the month of April 2013 on the following parameters.

	<u>Reported Value</u> <u>Monthly Avg.</u>	<u>Permit Limit</u> <u>Monthly Avg.</u>
a. TSS Concentration	51 mg/l	40 mg/l
b. TSS Loading	2078 pounds	1467.8 pounds

These violations occurred in part, because we had to draw down the lagoon, for the contractor to do some work. In addition we are continuing to have filter problems and are making repairs regularly. We should be able to stay in permit for the month of May, unless we have a major rainfall event. Construction continues on the expansion of the wastewater treatment plant, with an expected completion date of June 2014. If you have any other questions or comments feel free to call anytime.

Sincerely,


Eugene Townsley
Plant Superintendent

Cc: Mr. Damon Johnson P.E.