

BATESVILLE WASTEWATER TREATMENT PLANT

500 River Bank Road

Batesville, Arkansas 72501

Phone (870)-698-2442 Fax 870-698-2443

wwwsuper@cityofbatesville.com

September 13, 2012

NPDES ENFORCEMENT DIVISION

Arkansas Department of Environmental Quality

5301 Northshore Drive

North Little Rock, Arkansas 72118


RE: NPDES AR0020702 - - AFIN: 32-00044

This letter is to notify your office that the Batesville Wastewater Treatment Plant exceeded its discharge limit for the month of August 2012 on the following parameter.

	<u>Reported Value</u>	<u>Permit Limit</u>
	<u>Maximum</u>	<u>Maximum</u>
a. pH Concentration	10.05 S.U.	10.0 S.U.

We believe this violation occurred because of the heat and drought conditions in combination with the lagoon levels being kept lower than normal for construction. If you have any other questions or comments feel free to call anytime.

Sincerely,


Eugene Townsley
Plant Superintendent

Cc: Mr. Damon Johnson P.E.