

**BATESVILLE WASTEWATER TREATMENT PLANT**

**500 River Bank Road  
Batesville, Arkansas 72501  
Phone (870)-698-2442 Fax 870-698-2443  
wwsuper@cityofbatesville.com**

April 13, 2015

NPDES ENFORCEMENT DIVISION  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118


RE: NPDES AR0020702      AFIN: 32-00044

This letter is to notify your office that the Batesville Wastewater Treatment Plant exceeded its discharge limit for the month of March 2015, on the following parameters.

	<u>Reported Value</u>	<u>Permit Limit</u>
	<u>Monthly Avg.</u>	<u>Monthly Avg.</u>
a. BOD Loading	1916 pounds	1100.9 pounds
b. TSS Loading	2476 pounds	1467.8 pounds

These violations occurred in part due to the construction project and excessive rain and snow. We should be able to stay in permit for the month of April, unless we have major rainfall again. If you have any other questions or comments feel free to call anytime.

Sincerely;

  
Eugene Townsley  
Plant Superintendent

Cc: Mr. Damon Johnson P.E.