

**BATESVILLE WASTEWATER TREATMENT PLANT**

**500 River Bank Road  
Batesville, Arkansas 72501  
Phone (870)-698-2442 Fax 870-698-2443  
wwwsuper@cityofbatesville.com**

April 10, 2013

NPDES ENFORCEMENT DIVISION  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, Arkansas 72118


RE: NPDES AR0020702 - AFIN: 32-00044

This letter is to notify your office that the Batesville Wastewater Treatment Plant exceeded its discharge limit for the month of March 2013 on the following parameters.

	<u>Reported Value</u> <u>Monthly Avg.</u>	<u>Permit Limit</u> <u>Monthly Avg.</u>	<u>Reported Value</u> <u>Weekly Avg.</u>	<u>Permit Limit</u> <u>Weekly Avg.</u>
a. TSS Concentration	52 mg/l	40 mg/l	67 mg/l	60 mg/l
b. TSS Loading	2278 pounds	1467.8 pounds		

These violations occurred because of porous plate damage to the filters and extensive rainfall over the last few months. We have made several repairs to the filters, however the lagoons still remain high. As you may be aware, we are currently under construction to expand the wastewater treatment plant with an expected completion date of June 2014. If you have any other questions or comments feel free to call anytime.

Sincerely;

  
Eugene Townsley  
Plant Superintendent

Cc: Mr. Damon Johnson P.E.



**Batesville Wastewater Treatment Plant**

500 River Bank Road  
Batesville, Arkansas 72501

LITTLE ROCK AR

11 APR 2013 PM 4:11



Liberty  
FOREVER



Equality



Justice

NPDES Enforcement Division  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

72118531799

