



December 27, 2018

Honorable Joe Dillard, Mayor
City of Mountain Home
752 N. College Street
Mountain Home, AR 72653

email: city@cityofmountainhome.com

**RE: NPDES Permit Number: AR0021211, AFIN: 03-00039
Corrective Action Plan Response**

Dear Mayor Dillard,

The Department received and reviewed the Corrective Action Plan (CAP), dated December 11, 2018, for the above referenced facility. The response was deemed adequate with the following stipulations:

- Please provide an inclusive milestone schedule by January 18, 2018 that includes a final date of compliance.
- Please submit a liftstation evaluation, by March 1, 2019, to determine if all twelve (12) liftstations are adequately sized and properly operating.
- Please submit quarterly reports detailing the progress the City of Mountain Home has made in achieving final compliance with permit. The first quarterly report will be due by March 1, 2019.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0639 or you may e-mail me at bailey.taylor@adeq.state.ar.us.

Sincerely,

A handwritten signature in blue ink that reads "Bailey Taylor".

Bailey Taylor
Enforcement Coordinator
Office of Water Quality

cc: Terry Sanders, Plant Manager, City of Mountain Home (tsanders@cityofmountainhome.com)
Alma Clark, W&S Director, City of Mountain Home (aclark@cityofmountainhome.com)