

From: [J.L. Wagoner](#)
To: [Pemberton, Layne](#)
Subject: Report for citizen complaint at 200 North 7th St.
Date: Friday, June 23, 2017 10:32:12 AM

*J.L. Wagoner
Public Works Director
Work 870-453-8300
City of Flippin
P.O. Box 40
Flippin Ar. 72634*

200 North 7th St.

ADEQ notified the City of Flippin at 8:45am 6-23-2017 of a call to them of a overflowing manhole in a citizens yard. Call was taken by Public Works Director J.L. Wagoner. I went to the address to find a overflow that had occurred sometime in the past. The lid was on and the area was dry, I took a picture and sent it to Layne as I found the scene when I arrived. We have found no evidence of any contact to the city as caller states to ADEQ that the city knew of any overflow on 6-22-2017.

The last known probable cause for the overflow if from I & I would have been from the weekend of 6-3-17. That following monday we had 2in of rain in the gauge at the plant for over the weekend.

At this time the men are cleaning the area of the overgrowth and around the manhole from the overflow. The area will be hauled off to are wastewater sludge dumpster at the plant. They will lime the entire area and will replace the area back with topsoil. Will take pictures of area when done and report back today.

J.L. Wagoner
Public Works Director
City of Flippin

