

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021717 Discharge Number: 001-A

Facility: City of Flippin

Address: 222 East Industrial Park Road

City: Flippin State: AR Zip: 72634

Contact: J.L. Wagoner Phone: 870-453-8300

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
July 6, 2018	Nitrogen	Yes	Yes	
			Monthly AVG	2
			7 Day AVG	3
		Monthly AVG		3

We feel this problem was due to:

We were previously on bypass. We were running our rotors on timer during the bypass due to infiltration and sludge levels. When we went back online the DO level did not have enough time to put the ammonia nitrogen back within the discharge limitations.


We plan on correcting the problem in this manner:

Reducing inflow/infiltration. We are still in process of completing our sewer line inspections with ARWA. We will try to repair what we can to help with this problem, until we have completed our inspections.

Time estimated that it will take to correct problem:

We have been approved thru ANRC for part of the project. We are currently in the application process with USDA. When we have any information from USDA, we will let you know as soon as we find out anything. We are still estimating completion by November 2019 depending on the funding process.

Sincerely,


Authorized Signature

8-10-2018
Date