## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive North Little Rock, AR 72118

RE: NPDES Permit No: AR	<u>0021717</u>	Discharge Number:	001-A
acility:	City of Flippin		
Address: 222 East Industria	l Park Road		
City: Flippin	State: AR	Zip: <u>7263</u> 4	1
Contact: J.L Wagoner		Phone: 870-453-8300	

Date of Non-	Parameter	Quality or	Quality or	Permit Limits
Compliance	Exceeded	Loading	Concentration	
Aug 3 2022	CBOD	Yes	Yes	
			Monthly AVG	10
			7 Day	15
		Monthly AVG		15

We feel this problem was due to:

The treatment plant is in the construction stage.

We plan on correcting the problem in this manner:

Reducing inflow/infiltration. We have completed our sewer camera work and have turned it over to the engineers.

Time estimated that it will take to correct problem:

Spring 2023

Sincerely,

<u>JL Wagoner</u> 9/22/2022

## **Authorized Signature**

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)