

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021717 _____ Discharge Number 001-A

Facility: City of Flippin

Address: 222 East Industrial Park Road

City: Flippin State: AR Zip: 72634

Contact: J.L. Wagoner Phone: 870-453-8300

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
JUNE 6, 2018	NITROGEN	YES	YES	
			MONTHLY AVG	2
			7 DAY AVG	3
		MONYHLY AVG		3

We feel this problem was due to:

We were coming off the Bypass. We were running our rotors on a timer during the Bypass due to infiltration and sludge levels. When we went back online the, Do level did not have enough time to put the ammonia nitrogen back within the discharge limitations.

We Plan on correcting the problem in this manner:

Reducing inflow/ infiltration. We are still in process of completing our sewer line inspections with ARWA to put with our ANRC funding app. We will try to repair what we can to help with this problem, until we have completed our inspections.


Time estimated that it will take to correct problem:

Will find out about funding for our Wastewater system July 18th 2018. Estimated completion is October 2019 if funding is approved.

Sincerely,
J.L. Wagoner

Public Works Director


Authorized Signature


Date