

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR 0021717 Discharge Number: 001-A

Facility: City of FLIPPIN

Address: 222 EAST Industrial Park Road

City: FLIPPIN State: AR Zip: 72634

Contact: J.L. Wagener Phone: Office - 870-453-9300  
Cell - 870-405-0600

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
MAY 2, 2018	Nitrogen	YES	YES	
			MONTHLY AVG	2
			7 DAY AVG	3
		MONTHLY AVG		3

**We feel this problem was due to:**

We were coming OFF bypass which our rotors were on a time limit during the bypass. When we went back online the DO level did not have enough time to put the ammonia nitrogen back within the discharge parameters.

**We plan on correcting the problem in this manner:**

Reducing inflow/infiltration. We are getting close to completing our sewer camera inspections with ARWA to put with our ANRL Funding app. We repair what is within our means as found.

**Time estimated that it will take to correct problem:**

OCT. 2019

Sincerely,

J.L. Wagener  
 Authorized Signature

6-21-2018  
 Date