

Karren Thomas (adpce.ad)

From: Karren Thomas (adpce.ad)
Sent: Monday, December 5, 2022 1:43 PM
To: 'mayor@cityofflippin.com'
Cc: 'cofmaintenance@hotmail.com'; Thomas Harrington (adpce.ad)
Subject: AR0021717 Permit Effective November 1, 2022
Attachments: AR0021717 Significant Changes.pdf; AR0021717_Permit_Letter.pdf

Honorable Jerald Marberry,

Attached above is a Permit Letter that highlights information about your recently issued permit that became effective November 1, 2022.

Also included is a list of Significant Changes from the previously issued permit. (Permittee is responsible for carefully reading the permit in detail and becoming familiar with ALL the changes.)

If you have any questions, please call or e-mail the contact listed at the bottom of the letter.

Karren Thomas | Wastewater Licensing Extra Help
**Division of Environmental Quality | Office of Water Quality
Enforcement Section**
5301 Northshore Drive | North Little Rock, AR 72118
t: 501.682.0608 | f: 501.682.0880 | e: WWL@adeq.state.ar.us



ARKANSAS
ENERGY & ENVIRONMENT

Cc: [JL Wagoner, Public Works Director](mailto:JL.Wagoner@adeq.state.ar.us)
Thomas.harrington@adeq.state.ar.us

PERMIT LETTER



PERMIT INFORMATION

PERMIT NAME: _____

PERMIT #: _____

PERMIT LINK: _____



PERMIT EXPIRATION

PERMIT EXPIRES: _____

RENEWAL APPLICATION DUE DATE: _____



REPORTS

CAO/CAP COMPLIANCE SCHEDULE: _____

PERMIT COMPLIANCE SCHEDULE: _____



DISCHARGE MONITORING REPORT (DMR)

DMRs are due on the ___ of the month. A Cognizant or Responsible Official must have a CDX/NetDMR account to submit DMRs. If there are effluent violations, a Non-Compliance Report (NCR) must be attached to the DMR via NetDMR.



OPERATOR

My treatment plant requires a _____ Operator licensed in the State of Arkansas.



CONTACT ASSISTANCE

NAME: _____

TITLE: _____

PHONE NUMBER: _____ EMAIL: _____



ENVIRONMENTAL
QUALITY

AR0021717

SIGNIFICANT CHANGES FROM THE PREVIOUSLY ISSUED PERMIT

The permittee is responsible for carefully reading the permit in detail and becoming familiar with all of the changes therein:

1. The facility's mailing address and driving directions were removed from the cover page.
2. The coordinates for Outfall 001 were updated based on an inspection report dated August 18, 2020.
3. Tiered limits and requirements were added to Part I.A; Part I.A.1 was added for Tier I limits for the facility's existing, pre-construction treatment system and design flow of 0.175 MGD; Part I.A.2 was added for Tier II limits applicable for the post-construction treatment system and design flow of 0.35 MGD.
4. All existing mass limits and the concentration limits for TSS and NH₃-N in Part I.A were updated to one decimal place per updated Office of Water Quality (OWQ) rounding procedures.