



ARKANSAS ENERGY & ENVIRONMENT

August 23, 2023

Honorable, Jeffery A. Brown Mayor
City of DeQueen
P.O. Box 730
DeQueen, AR 71832

email: mayor@cityofdequeen.com

**RE: Permit Number: AR0021733, AFIN: 67-00023
Effluent Violation Warning Letter, Report and Request for Non-Compliance Reports**

Dear Mayor Brown:

A review of the Permit file for the above mentioned facility for the period of March 1, 2023 through June 30, 2023 revealed the following compliance issues:

The facility has reported **5 effluent violations** of Part I, Section A of Permit No. AR0021733

AR0021733 - DEQUEEN, CITY OF (67-00023)

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %	Vio Code
04/30/2023	001-A	Copper, total recoverable (MO AVG, lb/d)	0.73	.407	79%	Numeric Vio
04/30/2023	001-A	Copper, total recoverable (MO AVG, ug/L)	15.6	12.2	28%	Numeric Vio
05/31/2023	001-A	Copper, total recoverable (MO AVG, lb/d)	476.18	.407	116,898%	Numeric Vio
05/31/2023	001-A	Copper, total recoverable (MO AVG, ug/L)	23.4	12.2	92%	Numeric Vio
06/30/2023	001-A	Copper, total recoverable (MO AVG, ug/L)	16.7	12.2	37%	Numeric Vio

Non-compliance reports with corrective actions are required each month that a violation is reported and for each violation. The following Non- Compliance Reports (NCRs) have not been submitted:

- April 2023
- May 2023
- June 2023

Please submit the NCRs listed above by August 28, 2023.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-

682-0736, or you may e-mail me at thomas.harrington@adeq.state.ar.us.

Sincerely,

A handwritten signature in blue ink that reads "Thomas Harrington". The signature is written in a cursive style with a long horizontal stroke at the beginning.

Thomas Harrington
Enforcement Analyst, DEQ, OWQ
5301 Northshore Drive, North Little Rock, AR 72118

CC: Clint C. Young, Wastewater Operator, cyoung@cityofdequeen.com