

# ADEQ

ARKANSAS  
Department of Environmental Quality

October 19, 2011

Michael Sims  
City of DeQueen  
PO Box 730  
DeQueen, AR 71832

RE: NPDES Permit Number AR0021733, AFIN 67-00023

Dear Mr. Sims:

A recent review of the NPDES file for **City of DeQueen** has revealed the following violation for the monitoring period ending **08/31/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	Ammonia Nitrogen (Monthly Avg)	2.73	2	mg/L
001-A	Ammonia Nitrogen (7 Day Avg)	9.8	3	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0021733** and AFIN **67-00023** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0667 or e-mail [carlsonm@adeq.state.ar.us](mailto:carlsonm@adeq.state.ar.us).

Sincerely,



Michelle Bolenbaugh  
Enforcement Analyst  
Water Division Enforcement Branch