

Barber, Kyle

From: Warner, William <William.Warner@pilgrims.com>
Sent: Tuesday, October 04, 2016 11:36 AM
To: Barber, Kyle
Cc: Pease, Joseph; Townsend, Dave
Subject: RE: E-mail from the Staff Directory
Attachments: De Queen AR Pilgrims_Water Treatment RunOver_Corrected.pdf

Kyle,

After proof reading, I noticed the date on the first line needed to be corrected. Corrected copy attached via pdf. Thank You

William Warner
Complex Environmental Manager
Office: (870) 584-5373
Cell: (318) 623-4010



From: Barber, Kyle [<mailto:barber@adeq.state.ar.us>]
Sent: Tuesday, October 04, 2016 7:43 AM
To: Warner, William
Subject: RE: E-mail from the Staff Directory

William

Thank you. I'll have this entered.

Kyle Barber

Enforcement Analyst

Office of Water Quality

Arkansas Department of Environmental Quality

(501) 682-0823



From: William Warner
Pilgrim's Pride/Environmental Manager
October 3, 2016
De Queen Processing Plant
401 S 3rd St.
De Queen, AR 71832
RE: Effluent Water Treatment / Run Over

To: Kyle Barber
ADEQ /Water Division
5301 Northshore Dr
North Little Rock, Arkansas 72118

Mr. Kyle Barber:

Industrial User ID ARR0021733

On October 03, 2016 the De Queen processing plant discharged approximately 250 gallons composed of "treated water" from the wastewater pretreatment plant along the back corner of the wastewater facility. The water was released due to the effluent discharge pipe being temporarily blocked. The treated water had a neutral pH, ranging 7.1 – 7.4. *CLB Engineering Services* performed excavation to remove the soil affected.

Corrective action was immediately sought out following containment and cleanup. The construction of a permanent "slide" to hold water in the flume is being sought out in order to assist the De Queen City in weekend sampling.

Please contact with any additional questions or concerns by email (William.Warner@pilgrims.com) or phone (318-623-4010).

Best regards,

William Warner
Complex Environmental Manager

