

CITY OF DE QUEEN WASTEWATER PLANT
NONCOMPLIANCE REPORT
AR0021733

On the week of March 4-11 the Total Phosphorus average was 2.366 mg/l which is above the 2.00mg/l limit. We had been experiencing heavy rainfall prior to this and started pulling water back from the old pond. The Sodium Aluminate used for extra phosphorus treatment was not high enough and caused the higher number, the Sodium Aluminate was increased and the test results from the end of the week were under limits. In the future more Aluminate will be added prior to any pull back from the pond.

Any questions please call 870-642-5231.

Michael Sims
City of De Queen
Wastewater Manager
PO Box 730
De Queen Ar. 71832