

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of DeQueen wastewater treatment Plant

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71832

Contact: Clint Young Phone: 870-582-3799

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>8-22</u>	<u>NO3</u>	<u>11.7mg/l month</u>		<u>10.0 monthly</u>

We feel this problem was due to:

We feel the Problem was due to the chicken Plant in our town sent us high NO3 for a week.

We plan on correcting the problem in this manner:

We visited with them and they corrected there problem

Time estimated that it will take to correct problem:

Fixed now

Sincerely,

Clint Young
Authorized Signature

8-24-23
Date