

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of De Queen Wastewater Facility

Address: 670 S 9th Street

City: De Queen State: AR Zip: 71832

Contact: Clint Young Phone: 870-584-5231

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8-9-23	14.8 ug/l			12.2 ug/l


We feel this problem was due to:
We feel the problem is PH and algae.

We plan on correcting the problem in this manner:
We are adjusting PH coming into plant.

Time estimated that it will take to correct problem:
Hopefully within the next couple months.

Sincerely,

Authorized Signature



Date

9-21-23