

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 6706023

Facility: City of DeQueen wastewater Treatment Plant

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71832

Contact: Clint Young Phone: 870-582-3799

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>1-23</u>	<u>TP</u>	<u>2.92</u>		<u>2.92 7day average</u>

We feel this problem was due to:

We feel the problem was due to our chemical Not feeding consistently.

We plan on correcting the problem in this manner:

We have corrected the problem.

Time estimated that it will take to correct problem:

Fixed Now

Sincerely,

Clint Young
Authorized Signature

10-24-23
Date