

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of DeQueen wastewater Plant

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71832

Contact: Clint young Phone: 800-582-3799

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>6-23</u>	<u>Copper</u>	<u>16.7ug/l</u>		<u>12.2ug/l</u>

We feel this problem was due to:

Algae.

We plan on correcting the problem in this manner:

Try to control our algae and PH.

Time estimated that it will take to correct problem:

We have corrected it for now.

Sincerely,

Clint young
Authorized Signature

10-24-23
Date