

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of DeQueen wastewater Plant

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71832

Contact: Clint Young Phone: 870-582-3799

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3-22	1.017 TP	1.017		1.0mg/l monthly TP

We feel this problem was due to:

We feel the problem was due to rain and algae.

We plan on correcting the problem in this manner:

We have turned up our chemical to treat it.

Time estimated that it will take to correct problem:

Fixed now.

Sincerely,

  
Authorized Signature

10-24-23  
Date