

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of DeQueen Waste Water Plant

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71832

Contact: Clint Young Phone: 870-582-3789

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5-23	Copper	23.4 ug/l		12.2 ug/l

We feel this problem was due to:  
pH adjustment and algae.

We plan on correcting the problem in this manner:  
Trying to control the algae.

Time estimated that it will take to correct problem:  
Fixed for now. ~~10-24-23~~

Sincerely,

Clint Young  
Authorized Signature

10-24-23  
Date