

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of DeQueen wastewater Plant

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71832

Contact: Clint Young Phone: 870-642-5231

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<del>10-26-23</del> 10-26-23	Copper Usl	22.4 ug/l		12.2 ug/l

We feel this problem was due to:

Problem was due to algae from our pond. And PH adjustment.

We plan on correcting the problem in this manner:

We have our pond off flow and that should fix the algae problem. We are also having the water treatment plant raise there PH a little.

Time estimated that it will take to correct problem:

Next couple months

Sincerely,

  
Authorized Signature

11-20-23  
Date