

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0021733 Discharge Number: 67-00023

Facility: City of DeQueen waste water

Address: 670 south 9th street

City: DeQueen State: AR Zip: 71822

Contact: Clint young Phone: 870-582-3799

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
9-17-23	4.53 mg/l for the week			2.0 mg/L weekly
The month of September	1.44 msl			1.0 msl monthly

We feel this problem was due to:

We send off samples to Arkansas Analytical we feel like we sent an influent sample for that day rather than an Effluent. This one day put us out of compliance the month of September. We were under all other days.

We plan on correcting the problem in this manner:

Not sending the influent sample

Time estimated that it will take to correct problem:

Fixed problem.

Sincerely,

  
 \_\_\_\_\_  
 Authorized Signature

10-23-23  
 \_\_\_\_\_  
 Date