



# ARKANSAS ENERGY & ENVIRONMENT

December 16, 2020

Honorable Jeffery A. Brown, Mayor  
City of DeQueen  
P.O. Box 730  
DeQueen, AR 71832

email: [msims@cityofdequeen.com](mailto:msims@cityofdequeen.com)

RE: NPDES Permit Number AR0021733, AFIN 67-00026  
Permitted Effluent Limitation Violations

Dear Mayor Brown,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0021733 during the review period. DEQ requires the City of DeQueen to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at [gavin.gray@adeq.state.ar.us](mailto:gavin.gray@adeq.state.ar.us).

Sincerely,  


Gavin Gray  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
11/30/2020	001-A	Chlorine, total residual, INST MAX, mg/L	0.011	<b>0.03</b>	173%	E90	50060-1-0