

City of Nashville
426 North Main Street
Nashville, AR 71852

August 1, 2014

STATE OF ARKANSAS
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

Attn: Mr. Allen Anderson
Enforcement Assistant, NPDES

Re: Cyanide/Selenium Second Quarter, 2014

Dear Mr. Anderson:

Results on our second quarter DMR show a violation on all accounts. I contacted our Laboratory and they suggested it may have happened due to an old bottle with old H₂SO₄ contained for so long. Our results show before the sample cyanide was <5.00. Samples following also show results as <5.00 ug/L. We will continue to resample and monitor closely this situation and keep you informed.

If you have further questions of concern, please contact me at 870-845-4015.


Sincerely,



Larry Dunaway
Public Works Director

cc: 2014 File Binder

CITY OF NASHVILLE
LARRY DUNAWAY
PUBLIC WORKS
DIRECTOR
426 NORTH MAIN STREET
NASHVILLE, AR 71852



**Arkansas Department of
Environmental Quality
Attn: Mr. Allen Anderson
Enforcement Assistant, NPDES
5301 Northshore Drive
Little Rock, AR 72118-5317**