

June 22, 2011

Mr. Larry Dunaway Public Works Director City of Nashville 426 N. Main Street Nashville, AR 71852

RE: NPDES Permit No. AR0021776, AFIN 31-00036

Dear Mr. Dunaway:

A review of the NPDES file for the City of Nashville for April 1, 2011 thru April 30, 2011 revealed that the following compliance issues:

The facility reported 1 violations of Part I, Section A. of NPDES Permit No.: AR0021776. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
04/30/11	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	126	15

The DMR did not include a sample measurement for BOD, carbonaceous, 05 day, 20 C (MO AVG lb/d). A copy of the 04/30/2011, 001A DMR has been included for your convenience. Please submit a corrected DMR to the Department by June 29, 2011. <u>The DMR must include an original signature and date by the Principal Executive Officer or Authorized Agent. Photocopied signatures cannot be accepted.</u>

Furthermore, the Department is unable to accept the 03/31/11 001Q DMR because it was not completed properly. A copy of this DMR is also included. A corrected copy must be submitted to the Department by June 29, 2011.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at <u>anderson@adeq.state.ar.us</u>.

Sincerely,

Can anderson

Alan Anderson Enforcement Analyst Water Division / Enforcement Branch