

ADEQ

ARKANSAS
Department of Environmental Quality

September 8, 2016

Mr. Larry Dunaway
Public Works Director
City of Nashville
426 N. Main Street
Nashville, AR 71852

RE: NPDES Permit Number AR0021776 AFIN 31-00036
Effluent Violations

Dear Mr. Dunaway:

A file review of the above referenced permit revealed your facility has experienced six (6) effluent violations from January 1, 2016 through May 31, 2016. All six (6) violations were for Ammonia Nitrogen. Attached is a list of effluent violations that have occurred for your review.

The Department has not received a Non-Compliance Report (NCR) for the effluent violations above. Your Permit requires a NCR be submitted for any violation of permit parameters. For an NCR to be considered adequate, it must contain all of the following:

- (1) a description of the violations,
- (2) the reason for the violations,
- (3) the duration of the violations,
- (4) the corrective action being taken to eliminate the violations,
- (5) the compliance date or expected compliance date,
- (6) an original signature of the cognizant official.

Please submit an adequate NCR addressing the attached list of effluent violations. Also, please submit a report/plan detailing the corrective actions that you are taking or will take to achieve compliance with the terms of the above mentioned permit. The report/plan shall be received no later than **September 30, 2016**.

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit and may result in enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0636 or you may e-mail me at porterg@adeq.state.ar.us.

Sincerely,



Gina Porter
Enforcement Analyst
Water Division Enforcement Branch

9/8/2016

**DMR Effluent Violations 01/01/2016 -
09/08/2016**

**AR0021776 - NASHVILLE, CITY OF / Major
POTW - Effective: 07/01/2014**

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit	Vio %
01/31/2016	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	5.25	5	5%
02/29/2016	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	10.47	5	109%
02/29/2016	001-B	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	11	7.5	47%
03/31/2016	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	5.79	5	16%
03/31/2016	001-B	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	8.8	7.5	17%
04/30/2016	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	4.61	2.57	79%