

ADEQ

ARKANSAS
Department of Environmental Quality

August 1, 2011

Larry Dunaway
Public Works Director
City of Nashville
426 N. Main Street
Nashville, AR 71852

RE: NPDES Permit No. AR0021776, AFIN 31-00036

Dear Mr. Dunaway:

A review of the NPDES file for the City of Nashville for the monitoring period of May 1, 2011 thru May 31, 2011 reveals the following compliance issues:

The facility reported 3 violations of Part I, Section A. of NPDES Permit No.: AR0021776. The effluent violations reported on the DMRs are as follows:

| DMR End Date | Discharge | Parameter | Reported Value | Permit Limit |
|--------------|-----------|---|----------------|--------------|
| 05/31/11 | 001A | Nitrogen, ammonia total (as N) (MO AVG, lb/d) | 67 | 38 |
| 05/31/11 | 001A | Nitrogen, ammonia total (as N) (MO AVG, mg/L) | 4.22 | 2 |
| 05/31/11 | 001A | Nitrogen, ammonia total (as N) (7 DA AVG, mg/L) | 7.98 | 3 |

The Department expects the City of Nashville to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

