

September 7, 2011

Larry Dunaway Public Works Director City of Nashville 426 N. Main Street Nashville, AR 71852

RE: NPDES Permit No. AR0021776, AFIN 31-00036

Dear Mr. Dunaway:

A review of the NPDES file for the City of Nashville for the monitoring period of June 1, 2011 thru June 30, 2011 revealed the following compliance issues:

The facility reported 3 violations of Part I, Section A. of NPDES Permit No.: AR0021776. The effluent violations reported on the DMRs are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
06/30/11	001A	pH (Maximum SU)	9.2	9
06/30/11	001A	Solids, total suspended (MO AVG, mg/L)	16.4	15
06/30/11	001A	Solids, total suspended (7 DA AVG, mg/L)	33	22.5

The Department expects the City of Nashville to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at <a href="mailto:anderson@adeq.state.ar.us">anderson@adeq.state.ar.us</a>.

Sincerely,

Alan Anderson Enforcement Analyst

Water Division / Enforcement Branch

Alan anders