



ARKANSAS ENERGY & ENVIRONMENT

February 22, 2022

Honorable Billy Ray Jones, Mayor
City of Nashville
426 North Main
Nashville, AR 71852

EMAIL: m.woodruff@nashar.org

**RE: Permit Number: AR0021776, AFIN: 31-00036
Effluent Violation Warning Letter**

Dear Mayor Jones:

A review of the Permit file for the above mentioned facility for the period of June 1, 2021 through December 31, 2021 revealed the following violations of the permitted effluent discharge limitations:

The facility has reported **6 effluent violations** of Part I, Section A of Permit No. AR0021776:

DMR End Date	Discharge Number	Parameter Description	DMR Value Qualifier Code	Reported DMR Value	Permit Limit	Vio %
06/30/2021	001-B	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	=	3.03	3	1%
07/31/2021	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	=	2.08	2	4%
10/31/2021	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	=	3.19	2	60%
11/30/2021	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	=	6.6	5	32%
12/31/2021	001-B	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	=	148.8	146	2%
12/31/2021	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	=	5.45	5	9%

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0630, or you may e-mail me at allen-daniel@adeq.state.ar.us.

Sincerely,

Leslie Allen-Daniel
Enforcement Coordinator, DEQ, OWQ
5301 Northshore Drive, North Little Rock, AR 72118

cc: Larry Dunway, npw@nashar.org