

ADEQ

ARKANSAS
Department of Environmental Quality

June 1, 2011

Mr. Larry Dunaway
Public Works Director
City of Nashville
426 N. Main Street
Nashville, AR 71852

RE: NPDES Permit No. AR0021776, AFIN 31-00036

Dear Mr. Dunaway:

A review of the NPDES file for the City of Nashville for March 1, 2011 thru March 31, 2011 revealed that the following Discharge Monitoring Report (DMR) has not been received by the Department:

- DMR End Date 03/31/11, Discharge TX1Q.

Please submit the delinquent DMR and any applicable non-compliance report to the Department by June 7, 2011. The DMR must include an original signature and date by the Principal Executive Officer or Authorized Agent. Photocopied signatures cannot be accepted.

Furthermore, the facility reported 3 violations of Part I, Section A. of NPDES Permit No.: AR0021776. The effluent violations reported on the DMR are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
03/31/11	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	193.9	192
03/31/11	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	14.43	10
03/31/11	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	16.06	15

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

