

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021776 Discharge Number: 001-B

Facility: Nashville, City of Wastewater Treatment Plant

Address: 743 HWY 27 South

City: Nashville State: AR Zip: 71852

Contact: Larry Dunaway Phone: 870-845-4015

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 2018	CBOD	107.25	11 mg/L	10 mg/L Mo Avg
			17.21 mg/L	15 mg/L 7 DA Avg

We feel this problem was due to:

Putting our second aeration pond back in service.

We plan on correcting the problem in this manner:

The pond has since stabilized and our CBOD numbers are back within limits.

Time estimated that it will take to correct problem:

Putting our second aeration pond back in service.

Sincerely,


Authorized Signature

06/20/2018
Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NASHVILLE PUBLIC WORKS
426 N MAIN ST
NASHVILLE, AR 71852

SHREVEPORT
LA 710
21 JUN '18
PM 2 L

B88476.23

\$0.47 0

US POSTAGE
FIRST-CLASS
062S0009160086
FROM 71852



stamps.com stamps.com

ADEQ
NPDES Enforcement Section
Bailey Taylor
5301 Northshore Dr
North Little Rock, AR 72218

72118-531753

