

Lawrence, Myrl

From: Lawrence, Myrl
Sent: Tuesday, November 10, 2020 4:11 PM
To: 'm.woodruff@nashar.org'
Cc: npw@nashar.org
Subject: Effluent Limit Violations Permit AR0021776 Nashville



ARKANSAS
ENERGY & ENVIRONMENT

November 10, 2020

Honorable Billy Ray Jones
Mayor, City of Nashville
426 North Main Street
Nashville, AR 71852

**RE: NPDES Permit Number AR0021776 AFIN 31-00036, City of Nashville
Effluent Limit Violations**

Dear Mayor Jones,

The Discharge Monitoring Reports (DMR) submitted for the periods ending July 31, 2020, and August 31, 2020, indicated the following violations of the permitted effluent limits:

| Monitoring Period End Date | Dsch# | Parameter | Limit Value | DMR Value | % Vio | Violation Code | Parameter Code |
|----------------------------|-------|------------------------------------------------|-------------|--------------|-------------|----------------|----------------|
| 08/31/2020 | 001-B | Nitrogen, ammonia total [as N], 7 DA AVG, mg/L | 3 | 3.95 | 32% | E90 | 00610-1-0 |
| 07/31/2020 | 001-B | Nitrogen, ammonia total [as N], MO AVG, mg/L | 2 | 2.939 | 47% | E90 | 00610-1-0 |
| 07/31/2020 | 001-B | Nitrogen, ammonia total [as N], 7 DA AVG, mg/L | 3 | 8.64 | 188% | E90 | 00610-1-0 |

A non-compliance report was not received by DEQ for the July violation, and an adequate non-compliance report was received for the August violation. No violations were reported for the September reporting period, indicating the corrective actions undertaken were adequate to return to compliance. Please submit the non-compliance report for the July violation as soon as possible.

As a reminder, every violation is subject to enforcement action by this division. At this time, no additional actions are being proposed. Should additional violations occur, these violations will be taken into consideration when determining any future enforcement actions. Should you have additional questions, or desire additional information, please contact me directly.

Kindest Regards,



Myrl V Lawrence Jr | Enforcement Analyst
Division of Environmental Quality | Office of Water Quality
Enforcement Branch

5301 Northshore Drive, North Little Rock, AR 72118

t: 501.682.0699 | cell: 501.319.5055 | e: myrl.lawrence@adeq.state.ar.us

CC: Larry Dunaway, Director of Public Works, City of Nashville, npw@nashar.org

ARKANSAS DEPARTMENT OF ENERGY AND ENVIRONMENT